



X-RANGE ICX UNDERFLOOR OPTION WIRING DIAGRAM (For combi boiler installations)

230Vac 3amp
SWITCHED
FUSED SPUR




EARTH
NEUTRAL
LIVE

WIRING CENTRE





HOT WATER
TIMER



Orange & Grey
wires from underfloor
Zone are not required
Isolate and make safe.

DIGITAL TYPE 2 WIRE
ROOM THERMOSTAT



Parameter 081
must adjusted to
value '1'

ZONE VALVE
FLOW TO
UNDER FLOOR
V4043B
(NORMALLY OPEN)



Switched Live from
underfloor heating
controls to X3 Pin 2

